

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, KAITHAL

PHED
Haryana

Website :- <https://phedharyana.gov.in>

Memo No:- 115

Date:- 08/02/2024

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	KTL/04150/2/2024	Sample Details	Date & Time
Sample Classification:	Private	Collected By	OM PARKASH,9416365506
Sender:	OM PARKASH27974	Collection Date	05/02/2024 at 12:17
Location :-	PM SHRI GSSS SONGAL	Received at lab	05/02/2024 at 13:13
Latitude :-	76.467189	Tested at Lab	08/02/2024
Longitude :-	29.674126		

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/ APHA 9221C, 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in KAITHAL lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters, the water sample is found "**POTABLE**"



SUBHASH CHANDER, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, KAITHAL
email:- chemist.kaithal@phedharyana.gov.in

-----End of Report-----

Principal
PM SURI GSSS
Songal (Kaithal)